

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF-WWTP

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING November 2017

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX						
REPORTED VIOLATIONS	42.53	17.80						
PARAMETER VIOLATED	35.200	10.3						

WEEK OF Nov 08 17

Please fill out the following information

CAUSE OF VIOLATION Had some septic sludge and an extreme change in the elements that caused violation

DURATION OF VIOLATION November 2017

CORRECTIVE ACTION Got a good waste & lowered levels back to legal limits

EXPECTED COMPLIANCE DATE December 2017

Dustin Payne
SIGNATURE / DATE