

# REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING November 2019

PARAMETER VIOLATED	Chlorine, total residual	Chlorine, total residual						
REPORTED VIOLATIONS	0.33	0.31						
PARAMETER VIOLATED	< .011	< .011						

WEEK OF 11/06/19 11/29/19

*Please fill out the following information*

CAUSE OF VIOLATION We are continuing to experience problems with our wastewater plant  
we've replaced regulators and tubing and it was caused by our adjustable valve.

DURATION OF VIOLATION it has been replaced already however the problems will cease hopefully  
with the redesign of our plant

CORRECTIVE ACTION a complete redesign and overhaul of our wastewater plant will be  
the permanent correction

EXPECTED COMPLIANCE DATE construction date is unknown at this time, as soon as possible

  
 SIGNATURE / DATE