

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF-WWTP

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING November 2017

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX						
REPORTED VIOLATIONS	42.53	17.80						
PARAMETER VIOLATED	35.200	10.3						

WEEK OF Nov 08 17

*Please fill out the following information*

CAUSE OF VIOLATION Had some septic sludge and an extreme change in the elements that caused violation

DURATION OF VIOLATION November 2017

CORRECTIVE ACTION Got a good waste & lowered levels back to legal limits

EXPECTED COMPLIANCE DATE December 2017

Dustin Payne  
SIGNATURE / DATE