

# REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING October 2019

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	Chlorine total residual	Chlorine total residual		
REPORTED VIOLATIONS	19.09	6.4	8.50	4.20	3.90	0.74		
PARAMETER VIOLATED	13.30	3.9	3.9	3.9	0.011	0.011		
WEEK OF			10/02/19	10/23/19	10/02/19	10/23/19		

*Please fill out the following information*

CAUSE OF VIOLATION we are continuing to experience problems with our wastewater plants, the regulator is the cause of our current violation we've replaced one after another and cannot keep it going without experiencing problems

DURATION OF VIOLATION the current problem has already been fixed

CORRECTIVE ACTION to completely fix our problem, the redesign and construction on our wastewater plants should fix our current problems

EXPECTED COMPLIANCE DATE unknown as of yet, construction to begin as soon as possible

  
SIGNATURE / DATE