

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A  
Facility: CITY OF MELBOURNE WWTP  
Address: AR HWY 9 SPUR (CIRCLE DRIVE)  
City: MELBOURNE State: AR Zip: 72556  
Contact: Coy Dale Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10/25/23	FECAL 7 DAY GEO		> 2000.0	2000.0

We feel this problem was due to:

We feel this problem is to do with the state of the equipment at the wastewater facility many of our tools are old and need updated.

We plan on correcting the problem in this manner:

We plan on getting new equipment to monitor the wastewater plants.

Time estimated that it will take to correct problem:

We plan on getting it as soon as possible.

Sincerely,

Luas Champ

11-22-23

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)