



37 Treasure Creek
Greenbrier, Arkansas 72058

Phone: 501.224.1000
Fax: 501.499.6223

**CAO Quarterly Report
Melbourne Wastewater Treatment Plant
Permit Number: AR00020036, AFIN:33-00026**

Following is a report on the compliance efforts of the above referenced facility for the first quarter of 2023:

Discharge Violations

During the first quarter of 2023, the facility has experienced the following discharge violations:

Dissolved Oxygen, Minimum	0 violations
Fecal Coliform, Monthly Average	0 violation
Fecal Coliform, 7 Day Average	0 violations
Total Residual Chlorine	3 violations
Nitrogen, Ammonia, 7 Day Average	0 violation

The above violations were discussed with the operator. The operators have a hard time meeting the TRC limit and not have a fecal violation. Until the disinfection is changed from chlorine to UV these issues will continue.

SSES

Frozen and wet conditions prevented any progress on smoke testing.

Rehab/Upgrade Project

Funding from ARPA is still on the wait list. Conversations with ANRC reveal that the possibility of funding is getting more positive for the May ANRC commission meeting. An application with USDA to cover the portion not covered by ARPA is being reviewed .

James Dreher
Staff Engineer