

# ADEQ

ARKANSAS  
Department of Environmental Quality

June 21, 2011

Honorable Shannon Womack  
City of Melbourne  
P.O. Box 800  
Melbourne, AR 72556

RE: NPDES Permit No.: AR0020036, AFIN: 33-00026  
Response to Inspection

Dear Mayor Womack:

The Department has received your response dated May 16, 2011 to the April 14, 2011 inspection of your wastewater treatment facility by District Field Inspector Mike Kennedy. The response has been deemed inadequate by the Department.

The Department requires that the City of Melbourne submit a timeline for the connection of the lift stations and wells to the emergency generator.

A copy of the inspection report and the inadequate response are included with this letter for your review. Failure to adequately respond by July 21, 2011 will be considered in determining the enforcement action, if required, for this facility.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0635 or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,



Alan Anderson  
Enforcement Analyst  
Water Division Enforcement Section