

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING February 2016

PARAMETER VIOLATED

PARAMETER VIOLATED	C12 DAILY MAX	C12 DAILY MAX					
REPORTED VIOLATIONS	0.020	0.020					
PARAMETER VIOLATED	0.011	0.011					

WEEK OF Feb 03 16 Feb 24 16

Please fill out the following information

CAUSE OF VIOLATION

sulfur dioxide not mixing with effluent

properly

DURATION OF VIOLATION

February 2016

CORRECTIVE ACTION

working with chemical companies and Guy Lester from ADEQ to correct problem

EXPECTED COMPLIANCE DATE

March 2016

Dustin Payne

3/10/16

SIGNATURE / DATE

City of Melbourne
P.O. Box 800
Melbourne, AR 72556

LITTLE ROCK AR 722

07 APR 2016 PM 3 L



ADEQ
NPDES ENFORCEMENT

5301 Northshore Drive
North Little Rock, AR 72118

72118532801

