

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING January 2016

PARAMETER VIOLATED	Cl2 DAILY MAX	Cl2 DAILY MAX					
REPORTED VIOLATIONS	0.08	0.05					
PARAMETER VIOLATED	0.011	0.011					

WEEK OF Jan 06 16 Jan 27 16

*Please fill out the following information*

CAUSE OF VIOLATION Difuser malfunction

DURATION OF VIOLATION month of January

CORRECTIVE ACTION planning to dig down and replace difuser

EXPECTED COMPLIANCE DATE as soon as possible

Justin Payne


SIGNATURE / DATE

**City of Melbourne**

63 Municipal Dr.  
P.O. Box 800  
Melbourne, AR 72556

LITTLE ROCK AR 722

21 MAR 2016 PM 4 L



ADE Q  
NPDES ENFORCEMENT  
5301 Northshore Drive  
North Little Rock, AR 72118

72118531799

