

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING June 2016

PARAMETER VIOLATED	FECAL MAX						
REPORTED VIOLATIONS	984						
PARAMETER VIOLATED	400						

WEEK OF Jun 08 16

*Please fill out the following information*

CAUSE OF VIOLATION Lowering chlorine level to meet expectations  
combined with rain fall

DURATION OF VIOLATION 8 hrs.

CORRECTIVE ACTION rain stopped levels went back where they  
needed to be


EXPECTED COMPLIANCE DATE July

Dustin Payne 7-22-16  
SIGNATURE / DATE

City of Melbourne  
P.O. Box 800  
Melbourne, AR 72556

LITTLE ROCK AR 722

22 JUL 2015 PM 4.1



ADEQ  
NPDES ENFORCEMENT  
5301 Northshore Drive  
North Little Rock, AR 72118

72118-5301799

