

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF
PERMIT NUMBER AR0020036 001-A
PERIOD ENDING March 2015

PARAMETER VIOLATED	TSS CONC MO AVG	TSS CONC 7 DAY AVG MAX	TSS LDG MO AVG					
REPORTED VIOLATIONS	72.5	124.0	148.8					
PARAMETER VIOLATED	30.0	45.0	103.0					

WEEK OF Mar 04 15

Please fill out the following information

CAUSE OF VIOLATION The cause of violation was ^{due to} substantial rainfall on the week of violation causing excessive influent to plant.

DURATION OF VIOLATION 2 days

CORRECTIVE ACTION the rain subsided and levels went to plant compacity

EXPECTED COMPLIANCE DATE March 6, 2015

Justin Payne
SIGNATURE / DATE


City of Melbourne

P.O. Box 800

Melbourne, AR 72556

STON LITTLE ROCK AR 722

22 APR 2015 PM 4 L



**ADEQ
NPDES ENFORCEMENT**

5301 Northshore Drive
North Little Rock, AR 72118