

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING November 2014

PARAMETER VIOLATED	C12 DAILY MAX						
REPORTED VIOLATIONS	0.2						
PARAMETER VIOLATED	0.1						

WEEK OF Nov 05 14

Please fill out the following information

CAUSE OF VIOLATION Chlorinator on sulfur dioxide tank was slightly mis-adjusted.

DURATION OF VIOLATION maybe 12 hours

CORRECTIVE ACTION re-adjusted chlorinator and put more sulfur dioxide into contact chamber.

EXPECTED COMPLIANCE DATE November 6, 2014

Dustin Payne  
SIGNATURE / DATE

City of Melbourne.  
P.O. Box 800  
Melbourne, Ar 72584

LITTLE ROCK AR 722

26 DEC 2014 PM 3 L



ADEQ  
NPDES ENFORCEMENT  
5301 Northshore Drive  
North Little Rock, AR 72118

72118531799

