

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING September 2015

PARAMETER VIOLATED	Cl2 DAILY MAX	Cl2 DAILY MAX					
REPORTED VIOLATIONS	0.1	0.3					
PARAMETER VIOLATED	0.1	0.1					

WEEK OF Sep 02 15 Sep 23 15

Please fill out the following information

CAUSE OF VIOLATION having dual cylinders of sulfur dioxide when first cylinder ran out (emptied) the second pump malfunctioned.

DURATION OF VIOLATION an hour

CORRECTIVE ACTION replaced pump and cylinder

EXPECTED COMPLIANCE DATE September 23, 2015

Dustin Payne 10-16-15
SIGNATURE / DATE


City of Melbourne

P.O. Box 800

Melbourne, AR 72556

LITTLE ROCK AR 722

39 OCT 2015 PM 2:1



**ADEQ
NPDES ENFORCEMENT**

5301 Northshore Drive
North Little Rock, AR 72118

72118531799

