


Mayor:
Shannon Womack

Recorder/Treasurer:
Alecia K. Bray



Council Members:
William Wright
Jerry Crosby
Warren Smith
Trey Lamb
Ronnie Treat
Lee Melton

P.O. Box 800
63 Municipal Drive
Melbourne, AR 72556
Phone: (870) 368-4215
Fax: (870) 368-4721
Cityofmelbourne@centurytel.net

January 23, 2014

To whom it may concern:

ADEQ was notified on December 23rd, 2013, referring to an overflow violation due to excessive rain water influent. Problem was resolved by the subsidence of the storm within a few hours.

An overflow of a manhole on December 26th, 2013 resulted in an estimated 10,000 gallons of sludge. The problem was found to be faulty float switches that controlled the pumps. All three float switches were replaced, and everything was returned back to normal operation. If you have any future questions please feel free to give us a call at 870-368-4215.


Sincerely,

- Coy Dale
Water Superintendent

City of Melbourne
P.O. Box 800
Melbourne, AR 72556

LITTLE ROCK AR 722

28 JAN 2014 5M 4 L



ADEQ
NPDES Enforcement
5301 Northshore Drive
North Little Rock, AR 72118

72118531799

