



May 9, 2012

Mr. J.W. Beazley III, Manager
City of Forrest City
P.O. Box 816
Forrest City, AR 72336

RE: NPDES Permit Number AR0020087, AFIN 62-00070
NPDES Permit Effluent Violations

Dear Mr. Beazley:

A recent review of the above referenced permit has revealed the following violation for the monitoring period ending March 31, 2012.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	General Fecal Coliform (30 DA GEO)	1007	1000	#/100 mL

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0632 or e-mail at bolenbaugh@adeq.state.ar.us.

Thank you,

A handwritten signature in black ink, appearing to read "Jason R. Bolenbaugh".

Jason R. Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch