



A R K A N S A S  
Department of Environmental Quality

August 29, 2013

James Beazley III  
City of Forrest City  
P.O. Box 816  
Forrest City, AR 72336-0816

RE: NPDES Permit Number AR0020087, AFIN 62-00070  
NPDES Permit Effluent Violations

Dear Mr. Beazley,


A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending March 2013 and June 2013:

Monitoring Period	Discharge Number	Parameter	Violation	Limit
3/31/13	001-Q	Total Recoverable Copper (Mon. Avg. lbs/dy)	1.1	.52
3/31/13	001-Q	Total Recoverable Copper (Mon. Avg., mg/l)	70	29.47
3/31/13	001-Q	Total Recoverable Copper (7 Day Avg. mg/l)	70	59.14
6/30/13	001-Q	Total Recoverable Copper (Mon. Avg., lbs/dy)	0.80	.52
6/30/13	001-Q	Total Recoverable Copper (Mon. Avg., mg/l)	51	29.47
6/30/13	001-Q	Total Recoverable Copper (7 Day Avg., mg/l)	70	59.14

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0633 or e-mail at [schluterman@adeq.state.ar.us](mailto:schluterman@adeq.state.ar.us).

Sincerely,

A handwritten signature in cursive script that reads "Amy Schluterman". The signature is written in black ink on a white background.

Amy Schluterman  
Enforcement Analyst  
Water Division, Enforcement Branch