



ARKANSAS
Department of Environmental Quality

September 13, 2011

James W. Beazley, III
City of Forrest City
PO Box 816
Forrest City, AR 72335

RE: NPDES Permit Number AR0020087, AFIN 62-00070

Dear Mr. Beazley:

A recent review of the NPDES file for **City of Forrest City** has revealed the following violation for the monitoring period ending **05/31/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	TSS	533.6	354	lb/d
001-A	TSS	22.6	20	mg/l

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0020087** and AFIN **62-00070** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0667 or e-mail carlsonm@adeq.state.ar.us.

Sincerely,

Michelle Carlson
Enforcement Analyst
Water Division Enforcement Branch