



ARKANSAS
Department of Environmental Quality

October 28, 2016

The Honorable Larry Bryant
Mayor, City of Forrest City
303 North Rosser
Forrest City, AR 72336

RE: NPDES Permit Number AR0020087, AFIN 62-00070
NPDES Permit Effluent Violations

Dear Mayor Bryant:

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violation of the effluent limitations in Part I, Section A of your Permit for the reporting period ending June 30, 2016:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit
06/30/2016	001-A	Coliform, fecal general (30DA GEO, #/100mL)	4400	1000

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton
Enforcement Analyst
Office of Water Quality
NPDES Enforcement Section