



September 25, 2017

The Honorable Larry Bryant
Mayor, City of Forrest City
303 North Rosser
Forrest City, AR 72336

Email <larrysbryant@gmail.com>

RE: NPDES Permit Number AR0020087, AFIN 62-00070
NPDES Permit Effluent Violations

Dear Mayor Bryant:

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violation of the effluent limitations in Part I, Section A of your Permit for the reporting period ending July 31, 2017:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
07/31/2017	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	3233	62%

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or via e-mail at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton
Enforcement Analyst
Office of Water Quality, NPDES Enforcement Section

CC: Calvin Murdock <whcm2@aol.com>