

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Feb. 12th, 2020	Dissolved Oxygen		6.0 mg/L	7.0 mg/L Instantaneous Minimum
February, 2020	TSS	99.0 lb/d		91.0 lb/d Mo. Avg.
Feb. 19th, 2020	Fc		425 cfu/100 mls	400 cfu/100 mls 7 Day Geometric

We feel this problem was due to: RAIN, I&I Trouble

We plan on correcting the problem in this manner: WORK ON I&I CWB Engineers

Time estimated that it will take to correct the problem/s: NO IDEA!

Sincerely,

Jackie E Craig
Authorized Signature

3-26-20
Date