

August 3, 2015

Honorable Roger Gardner, Mayor CITY OF Mountain View P.O. Box 360 Mountain View, AR 72560

RE: NPDES Permit Number AR0020117 AFIN 69-00011

Dear Mayor Gardner,

A review of the NPDES file for the above mentioned facility for the period of July 2012 through June 2015 reveals the following compliance issues:

The facility has reported <u>12 effluent violations</u> of Part I, Section A of NPDES Permit No. AR0020117. <u>1 violation was for Biological Oxygen Demand (BOD), 1 violation was for Fecal</u> <u>Coliform, and 10 violations were for Total Nitrogen, Ammonia.</u> A detailed list of the violations has been included with this letter.

Additionally, the City of Mountain View has reported 33 Sanitary Sewer Overflows totaling over 147,000 gallons in the 36 month review period. Sanitary Sewer Overflows are an unpermitted discharge and the Department expects the City of Mountain View to work towards eliminating them

The Department is requesting the City submit a Corrective Action Plan detailing the measures that are being taken or will be taken to bring the facility into compliance with Permit effluent limits and to reduce Sanitary Sewer Overflows. Please provide <u>a date you expect to achieve</u> <u>compliance</u> with the effluent limits outlined in Part I, Section A of NPDES Permit Number AR0020117. Please submit the requested report by <u>August 21, 2015</u>.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0636, or you may e-mail me at <u>porterg@adeq.state.ar.us</u>.

Sincerely,

lona Porter

Gina Porter Enforcement Analyst Water Division, Enforcement Branch

AR0020117 - MOUNTAIN VIEW, CITY OF / Minor POTW - Effective: 08/01/2013

Discharge Number	Parameter Description	Monitoring Period End Date	Reported DMR Value	Permit Limit	Vio %	Violation Type	DMR Value Type Code	Parameter- Mon. Location- Season	Outfall	Parameter Code
001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	04/30/2013	33.2	23.7	40%	Numeric Vio	Q1	00610-1-0	001	00610
001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	04/30/2013	11.2	3.9	187%	Numeric Vio	C2	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	04/30/2013	16.2	3.9	315%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	06/30/2013	4.8	3.9	23%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	04/30/2014	3.97	3.9	2%	Numeric Vio	C2	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	04/30/2014	4.98	3.9	28%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	05/31/2014	4.5	3.9	15%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	07/31/2014	4.6	3.9	18%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	09/30/2014	8.3	3.9	113%	Numeric Vio	C3	00610-1-0	001	
001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	10/31/2014	6	3.9	54%	Numeric Vio	C3	00610-1-0	001	
# of Vios =	10									00610

Discharge Number	Parameter Description	Monitoring Period End Date	Reported DMR Value			Violation Type	DMR Value Type Code	Parameter- Mon. Location- Season	Outfall	Parameter Code
001-A	Coliform, fecal general (7 DA GEO, #/100mL)	05/31/2015	3000	400	650%	Numeric Vio	C3	74055-1-0	001	74055
# of Vios =	1									74055

Discharge Number	Parameter Description	Monitoring Period End Date	Reported DMR Value		Vio %	Violation Type	DMR Value Type Code	Parameter- Mon. Location- Season	Outfall	Parameter Code
001-A	BOD, carbonaceous [5 day, 20 C] (7 DA AVG, mg/L	01/31/2015	19.9	15	33%	Numeric Vio	C3	80082-1-0	001	80082
# of Vios =	1									80082