



ARKANSAS
Department of Environmental Quality

Facility: City of Mountain View ARG640093/AR0020117

Date: April 10, 2018

MEETING ATTENDANCE

Name	Organization	Job Title	E-Mail Address	Telephone Number
Bailey Taylor	ADEQ	Enforcement Analyst	bailey.taylor@adeq.state.ar.us	501-682-0639
Richard Healey	ADEQ	Enf. Branch Manager	Healey@adeq.state.ar.us	501-682-0640
Bryan Leamons	ADEQ	Sr. Ops Manager	leamons@adeq.state.ar.us	501-683-5406
Patrick Travers	ADEQ	Grants Manager	Patrick.travers@adeq.state.ar.us	501-682-0629
Jason Bolenbaugh	ADEQ	Compliance Branch Manger	Bolenbaugh@adeq.state.ar.us	501-682-0659
Caleb Osborne	ADEQ	Deputy Director	osbornec@adeq.state.ar.us	501-682-0655
Boger Gardner		Mayor	CityHall @ City of Mt View, com	870-269-3804
Krista Johnson	MTN View Water Plant	Operator M.O. Plant	AKH Water @ TNSoud.com	870-269-8686
Adam Triche	MCE	Engineer	atriche@mce-us.com	501-371-0272
Carrie McElhine	ADEQ	Eng. Supervisor	mawilliams2@adeq.state.ar.us	501-682-0915

REMARKS:

AGENDA

City of Mountain View

Tuesday, April 10, 2018 at 10:30am

1. Introductions and meeting sign in sheet

2. Proposed CAO for ARG640093:

- a. Using portable pump to discharge from wet well (unpermitted discharge)
- b. Sludge ponds and drying beds in need of maintenance.
 - i. Since the inspection, the City has removed sludge from one drying bed (119,000 gallons sent to Denali)
 - ii. No staff gauge in the pond – the City should decide on a sludge removal schedule and include what depth the staff gauge can read before sludge removal is necessary.
- c. Sediment basin plans were submitted as “future additions” but the Permit requires a construction permit for installation of sediment basins.
- d. The City discharges as Tier 3 but flows reported on the DMR indicate the City is discharging at a higher rate than Tier 3 allows. It’s possible the flow is being recorded or reported wrong.

3. Proposed CAO for AR0020117:

- a. CAP request 8/3/15 for effluent violations and SSOs
 - i. The City has been working on their collection system since 2010. Including pipe bursting, smoke testing, and removed a pump station with a gravity line.
- b. Reported fish kill 3/31/17 – City says there has never been any fish in that creek.
- c. Inspection 11/21/17 noted excessive I&I
 - i. Order & Agreement: Conduct SSES type study
- d. Department will consider penalty paid for ARG640093 when issuing CAO for AR0020117.

4. Response and/or follow-up if necessary.

- a. P.E. Certified plans and specs for sediment ponds and Form 1 for construction only.
- b. City should conduct a sludge pond survey vs. use the original design specs.