

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 8/01/2016 - 8/31/2016

FROM: City of Mtn.View
340 Westwood Ave, Off Hwy 66 W
Mountain View, AR 72560

DATE: 9/15/2016

PERMIT #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia was reported over the 7 day avg permit limit one time in August.
The Fecal Coliform was reported over the 7 day Geo permit limit one time in August.

3. CAUSE FOR NON-COMPLIANCE:

*12.4" of RAIN Aug
washout*

4. DURATION OF NON-COMPLIANCE:

The Ammonia violation took place on August 2nd, 2016.
The Fecal Coliform violation took place on August 18th, 2016

5. CORRECTIVE ACTION BEING TAKEN:

I+I


SIGNATURE: _____



**MOUNTAIN VIEW
WATER & SEWER DEPARTMENT
PO BOX 360
MOUNTAIN VIEW, AR 72560**

LITTLE ROCK, AR 72202

21 SEP 2016 PM 3:11



**ADEQ
NPDES Enforcement Section
5301 Northshore Drive
N. Little Rock, AR 72118-5317**

72118-5317

