

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Jesse Dandridge

Phone: 432-703-7611

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August, 2022	NO2+NO3		10.6 mg/L	10 mg/L 7 day Avg limit
August, 2022	Fc		1560 cfu/100mls	400 cfu/100mls 7 day Geo limit

We feel this problem was due to:

Rain IdT, Also 2/V problems

We plan on correcting the problem in this manner:

Salt Engineer's is in process of fixing issues - working on it.

Time estimated that it will take to correct the problem/s:

Very soon

Sincerely,

Jesse Dandridge  
Authorized Signature

10-5-2022

Date