

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020117 Discharge Number: 001-A

Facility: CITY OF MOUNTAIN VIEW - MOUNTAIN VIEW WASTEWATER TREATMENT PLANT

Address: 340 WESTWOOD AVE.

City: MOUNTAIN VIEW State: AR Zip: 72560

Contact: Jesse Dandridge Phone: 432-703-7611 or 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
JANUARY	TSS MONTHLY AVERAGE	163.61		91.0
JANUARY	TSS MONTHLY AVERAGE		17.3	15.0
JANUARY	FECAL 30 DAY GEO		4453.0	200.0
1/12/23	FECAL 7 DAY GEO		3130.0	400.0

We feel this problem was due to:

Lot Rain I&I Problem and UV System soon to be replaced.

We plan on correcting the problem in this manner:

Salt Engineering is in process of getting these issues fixed.

Time estimated that it will take to correct problem:

Very soon.

Sincerely,

Jesse Dandridge

2/23/2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)