

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Jackie Craig Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 3,10,17th,2021	Fc		353 cfu/100mls Avg	200 cfu/100mls 30 day geometric Avg limit
March 17th, 2021	DO		5.1 mg/L	7.0 mg/L Inst. Min limit

We feel this problem was due to: RAIN I-I High Flow

We plan on correcting the problem in this manner: CWB Eng

Time estimated that it will take to correct the problem/s: NOT SURE

Sincerely,

Jackie E Craig
Authorized Signature

4-23-21
Date