

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Jackie Craig Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May, 12,18th, 2021	Fc		3900 cfu/100mls	400 cfu/100mls 7 day geometric Avg limit
May 12th, 2021	NH3		4.2 mg/L	3.9 mg/L 7 Day Avg limit

We feel this problem was due to: RAIN I+I

We plan on correcting the problem in this manner: CWB Engineers

Time estimated that it will take to correct the problem/s: NOT SURE

Sincerely,

Jackie Craig
Authorized Signature

6-25-21
Date