

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Jackie Craig

Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May, 2022	Fc		1148 cfu/100mls	200 cfu/100mls Mo. geometric limit

We feel this problem was due to:

UV system

We plan on correcting the problem in this manner:

SALT Engineers are Fixing To start Repair works,

Time estimated that it will take to correct the problem/s:

Very soon

Sincerely,

Jackie E Craig
Authorized Signature

6-23-22
Date