

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
October 24th, 2018	Nitrate+Nitrate	11.0 mg/L 7day Avg	10.0 mg/L 7day Avg

We feel this problem was due to: OVER AIREATION

We plan on correcting the problem in this manner: TURN DOWN AIREATORS

Time estimated that it will take to correct the problem/s: ONE DAY

Sincerely,

Jackie E Craig
Authorized Signature

11-14-18
Date