

# NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment  
Division of Environmental Quality  
Office of Water Quality, Enforcement Section  
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0020117 Discharge Number: 001-A

Facility: CITY OF MOUNTAIN VIEW - MOUNTAIN VIEW WASTEWATER TREATMENT PLANT

Address: 340 WESTWOOD AVE.

City: MOUNTAIN VIEW State: AR Zip: 72560

Contact: Jesse Dandridge Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
OCTOBER	FECAL 30 DAY GEO		4932.0	200.0
10/5/23	FECAL 7 DAY GEO		8180.0	400.0
10/12/23	FECAL 7 DAY GEO		4120.0	400.0
10/19/23	FECAL 7 DAY GEO		3560.0	400.0

We feel this problem was due to:

UV and I&I Problem.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

We plan on correcting the problem in this manner:

Salt Engineering is in process of fixing the issues.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Time estimated that it will take to correct problem:

Very Soon.  
\_\_\_\_\_  
\_\_\_\_\_

Sincerely,

Jesse Dandridge

11/20/23

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)