

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0020117 Discharge Number: 001-A

Facility: CITY OF MOUNTAIN VIEW - MOUNTAIN VIEW WASTEWATER TREATMENT PLANT

Address: 340 WESTWOOD AVE.

City: MOUNTAIN VIEW State: AR Zip: 72560

Contact: Jesse Dandridge Phone: 1-870-269-8283

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
SEPTEMBER	FECAL 30 DAY GEO		> 2839.0	200.0
9/7/23	FECAL 7 DAY GEO		4160.0	400.0
9/14/23	FECAL 7 DAY GEO		2750.0	400.0
9/20/23	FECAL 7 DAY GEO		> 2000.0	400.0

We feel this problem was due to:

UV and I&I Problems

We plan on correcting the problem in this manner:

Contractors are working on the problem

Time estimated that it will take to correct problem:

Salt Engineering on the issue ASAP

Sincerely,

Jesse Dandridge

10/24/2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)