

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Jesse Dandridge

Phone: 432-703-7611

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
September, 2022	Fc		780 cfu/100mls	400 cfu/100mls 7day limit
September, 2022	NO2+NO3		11.8 mg/l	10 mg/l 7day Avg

We feel this problem was due to:

Rain and A I&I issue, also PV problem's.

We plan on correcting the problem in this manner:

S&I Engineering is in process of fixing issues "Working On It"

Time estimated that it will take to correct the problem/s:

Soon

Sincerely,

Jesse Dandridge
Authorized Signature


10-25
2022
Date