

# NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 4/01/2018 - 4/30/2018

**FROM:** City of Mtn.View  
340 Westwood Ave, Off Hwy 66 W  
Mountain View, AR 72560

**DATE:** 5/18/2018

**PERMIT #:** AR0020117

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

There was a soft non compliance for the Fecal Coliform exceeding permit limits in April.

3. CAUSE FOR NON-COMPLIANCE:

Rain or I&I caused flow to go up.

4. DURATION OF NON-COMPLIANCE:

The soft non compliance description above took place on April 17th, 2018.

5. CORRECTIVE ACTION BEING TAKEN:

Flow went back down.

SIGNATURE: \_\_\_\_\_ Jackie E Craig II