

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
April 8th, 2020	Dissolved Oxygen		6.5 mg/L	7.0 mg/L Instantaneous Minimum

We feel this problem was due to:

under aeration!

We plan on correcting the problem in this manner:

Adjust aeration

Time estimated that it will take to correct the problem/s:

Done!

Sincerely,

Jackie E. Craig
Authorized Signature

5-26-20
Date