

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August 14th, 2019	Fecal Coliform		490 cfu/100mls	400 cfu/100mls 7 Day Average
August 6th, 2019	Ammonia	35.8 lb/d Mo. Avg	7.4 Avg & 16.6 7day	23.7 lb/d Mo Avg & 3.9 mg/L 30 day Avg & 7 day Avg

We feel this problem was due to: Airaction!

We plan on correcting the problem in this manner: Fix Beering in Airaction!

Time estimated that it will take to correct the problem/s: AS SOON AS POSSIBLE!

Sincerely,

Joe Thatcher
 Authorized Signature

9-24-19
 Date