

# NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 8/01/2018 -8/31/2018

**FROM:** City of Mtn.View  
340 Westwood Ave, Off Hwy 66 W  
Mountain View, AR 72560

**DATE:** 9/14/2018

**PERMIT #:** AR0020117

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded permit limits once during the month of August.

3. CAUSE FOR NON-COMPLIANCE:

Excessive Rain

4. DURATION OF NON-COMPLIANCE:

The soft non compliance description above took place on August 15th, 2018.

5. CORRECTIVE ACTION BEING TAKEN:

was in storm flow mode!  
Put back in regular flow mode!  
PLANT got upset! All good now.

SIGNATURE:

Jackie E Craig