

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
December 4th, 2019	Dissolved Oxygen		6.7 mg/L	7.0 mg/L Instantaneous Minimum

We feel this problem was due to:

Airreactor's TURN TO LOW!

We plan on correcting the problem in this manner:

TURN Airreactor's UP!

Time estimated that it will take to correct the problem/s:

ALL Ready Done!

Sincerely,

Jackie E. Coyle
Authorized Signature

1-24-20
Date