

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Jackie Craig

Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Feb 22,24,26th, 2021	Fc		300 cfu/100mls	200 cfu/100mls 30 day geometric Avg limit
Feb 22,24,26th, 2021	DO		6.3 mg/L	7.0 mg/L Inst. Minimum limit
Feb 22,24,26th, 2021	CBOD	67.5 lb/d Mo Avg		60.9 lb/d Mo Avg

We feel this problem was due to:

RAIN, I+I problem!

We plan on correcting the problem in this manner:

CWB Eng

Time estimated that it will take to correct the problem/s:

NOT SURE right now!

Sincerely,

  
Authorized Signature

3-24-21  
Date