

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117      Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Jackie Craig

Phone: 870-213-7222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Jan 13,22,27th 2021	Fc		272 cfu/100mls	200 cfu/100mls 30 day geometric Avg limit

We feel this problem was due to: RAIN I-I problem

We plan on correcting the problem in this manner: CWB ENGINEERS IS WORKING ON IT.

Time estimated that it will take to correct the problem/s: I DON'T NO!

Sincerely,

Jackie Craig  
Authorized Signature

2-24-21  
Date