

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
July 10th, 2019	Dissolved Oxygen		5.7 mg/L	6.0 mg/L Instantaneous Minimum
July 9th, 16th, 23rd 2019	Ammonia	23.9 lb/d	5.1 Avg & 10.0 7day	23.7 lb/d Mo Avg & 3.9 mg/L 30 day Avg & 7 day Avg

We feel this problem was due to:

Equipment Fail on AERATOR


We plan on correcting the problem in this manner:

As soon as possible Replace Bearing!

Time estimated that it will take to correct the problem/s:

As soon as possible!

Sincerely,


Authorized Signature

8-20-19
Date