

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
July 8,22,29th 2020	Fc		255 cfu/100mls	200 cfu/100mls 30 day geometric Avg limit

We feel this problem was due to:

Problems with P.O. probes!

We plan on correcting the problem in this manner:

Bolton Electric + Controls, Inc

Time estimated that it will take to correct the problem/s:

Hopefully soon!

Sincerely,


Authorized Signature

8-25-20
Date