

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 6/01/2017 - 6/30/2017

FROM: City of Mtn. View
340 Westwood Ave, Off Hwy 66 W
Mountain View, AR 72560

DATE: 7/11/2017

PERMIT #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia nitrogen exceeded the 7 day average permit limit during the month of June.

3. CAUSE FOR NON-COMPLIANCE:

*Water coming from drying beds
was high in Ammonia due to RAIN.
Increased Aeration*

4. DURATION OF NON-COMPLIANCE:

The non compliance description above took place on June 15th, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

*Increased
Aeration*

SIGNATURE: _____

Joe Mateter