

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

| Date of Non-Compliance | Parameter Exceeded | Quality or Concentration | Permit Limits |
|-----------------------------|--------------------|---------------------------------|---------------------------------|
| March 6th, 20th, 27th, 2019 | Fecal Coliform | 223 col/100mls 30 Day Geometric | 200 col/100mls 30 day Geometric |
| March 26th, 2019 | Nitrate + Nitrite | 11.0 mg/L 7 day Avg | 10.0 mg/L 7 day Avg |
| | | | |
| | | | |

We feel this problem was due to:

RAIN, I-I

We plan on correcting the problem in this manner:

FIND AND FIX I-I

Time estimated that it will take to correct the problem/s:

I DON'T NO!

Sincerely,

Jackie E Craig
Authorized Signature

4-18-19
Date