

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 24th, 2020	Nitrate + Nitrite		37.0 mg/L	10.0 mg/L 7 Day Avg. Permit Limit

We feel this problem was due to: OVER AERATION

We plan on correcting the problem in this manner: Fixing D.O. probes AND programming.

Time estimated that it will take to correct the problem/s: ALREADY Fixed!

Sincerely,

Joshua E. Craig JR
Authorized Signature

5-4-20
Date

RECEIVED
Date: 5-4-2020
11:10 AM