

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117      Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 12th, 2020	TSS	167.6 lb/d Mo. Avg	30.0 mg/L 7 Day Avg	91 lb/d Mo Avg & 23.0 mg/L 7 Day Avg.

We feel this problem was due to:

RAIN T-I

We plan on correcting the problem in this manner:

WORK ON T-I, CWB Engineers

Time estimated that it will take to correct the problem/s:

NO IDEA!

Sincerely,

Jackie E. Craig  
Authorized Signature

6-29-20  
Date