

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
Nov. 7th, 14th & 28th, 2018	Fecal Coliform	2,000, 3,360, 760 col/100ml	200 30day Geo 400 7day Avg
Nov. 28th, 2018	Nitrate+Nitrate	14.0 mg/L 7day Avg	10.0 mg/L 7day Avg

We feel this problem was due to:

*RAIN, I-I problems, High FLOW ALL MONTH!
PLANT STAYED upset ALL MONTH!*

We plan on correcting the problem in this manner:

work on I-I

Time estimated that it will take to correct the problem/s:

Some Time

Sincerely,

Joe Thatcher
Authorized Signature

12-18-18
Date

RECEIVED
Date: *12-18-18 DW*