

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117

Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
Nov 4th,13th,18th 2020	Fecal Coliform	201 cfu/100mls 30 day Geometric	200 cfu/100mls 30 day Geometric

We feel this problem was due to:

High Flow due to I-I Rain

We plan on correcting the problem in this manner:

CWB Engineers working on it

Time estimated that it will take to correct the problem/s:

NOT SURE!

Sincerely,

Jackie E. Craig
Authorized Signature

12-28-20
Date