

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View

State: AR

Zip: 72560

Contact: Joe Thatcher

Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
September 12th, 19th, 2018	Fecal Coliform	381 col/100ml 760 col/100ml	200 30day Geo 400 7day Avg
September 11th, 2018	Nitrate+Nitrate	14.0 mg/L 7day Avg	10.0 mg/L 7day Avg

We feel this problem was due to: Plant stayed in storm flow to long, was not getting full treatment!

We plan on correcting the problem in this manner: Putting plant in regular mode to achieve full treatment

Time estimated that it will take to correct the problem/s: Already Done!

Sincerely,

Jacob E Craig
Authorized Signature

10-23-18
Date