

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020117 Discharge Number: 001-A-Monthly

Facility: City of Mountain View

Address: 340 Westwood Ave, Off Hwy 66 W

City: Mountain View State: AR Zip: 72560

Contact: Joe Thatcher Phone: 870-213-6515

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
September, 2019	Fecal Coliform		227 (30 Day Geo)	200 cfu/100mls (30 Day Geo)
September, 2019	Ammonia	143.8 lb/d	35.7 Avg & 75.5 7day	23.7 lb/d Mo Avg & 3.9 mg/L 30 day Avg & 7 day Avg

We feel this problem was due to: Air emissions!

We plan on correcting the problem in this manner: Fix Bearing in Airerator!

Time estimated that it will take to correct the problem/s: waiting on parts!

Sincerely,
Joakin E. Camp
Authorized Signature

10-22-19
Date