

February 19, 2020

Honorable Roger Gardner, Mayor  
City of Mountain View  
P.O. Box 360  
Mountain View, AR 72560

email: [cityhall@mtnviewcity.com](mailto:cityhall@mtnviewcity.com)

**RE: NPDES Permit Number: AR0020117, AFIN: 69-00011  
Corrective Action Plan Response**

Dear Mayor Gardner,

DEQ received and reviewed the Preliminary Engineering Report (PER), submitted on February 18, 2020, for the above referenced facility. The response was deemed adequate with the following comments:

- Please be advised that, Pursuant to Regulation 6.202(A), “Any person who desires to construct, operate or modify any disposal system which will discharge to the waters of the State... shall submit an application for a permit for such activity.” Therefore, before beginning any construction projects, including significant operational or physical alterations, please submit a State Construction Permit application to the DEQ’s Office of Water Quality Permit Branch.
- The addition of a second final clarifier and increase of the design flow would also require a major permit modification. It is recommended that the City of Mountain View contact DEQ for the preliminary NPDES permit limits with the increased design flow.
- The City of Mountain View will be required to get the approval from Arkansas Department of Health regarding the collection system improvement project.
- If the construction activities will disturb greater than or equal to one (1) acre and less than five (5) acres, the City of Mountain View shall comply with the requirements in APC&EC Regulation No. 6.203 for stormwater discharge associated with a small construction site. If the construction site will disturb five (5) acres or more, the City of Mountain View shall comply with the terms of the storm water Construction General Permit Number ARR150000 prior to the start of construction.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0639 or by e-mail at [bailey.taylor@adeq.state.ar.us](mailto:bailey.taylor@adeq.state.ar.us).

Sincerely,



Bailey Taylor  
Enforcement Coordinator  
Office of Water Quality

cc: Jackie Craig, Wastewater Operator, City of Mountain View ([mtnviewsewer@gmail.com](mailto:mtnviewsewer@gmail.com))  
Kyle Breckenridge, P.E., CWB Engineers ([kbreckenridge@cwbenigneers.com](mailto:kbreckenridge@cwbenigneers.com))

**Division of Environmental Quality**

5301 Northshore Drive, North Little Rock, AR 72118  
[adeq.state.ar.us](http://adeq.state.ar.us)